



**BUREAU
VERITAS**

Certificate of compliance

Applicant: SolaX power Co., Ltd.
No. 288 Shizhu Road, Tonglu Economic Development Zone,
Dongxing District 311500, Tonglu City, Zhejiang Province
China

Product: Photovoltaic (PV) Inverter

Model: X1-1.1-S-D, X1-1.1-S-N, X1-1.5-S-D, X1-1.5-S-N,
X1-2.0-S-D, X1-2.0-S-N, X1-2.5-S-D, X1-2.5-S-N,
X1-3.0-S-D, X1-3.0-S-N, X1-3.3-S-D, X1-3.3-S-N

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with C10/11 – 06.2012 Appendix 4 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with insulating function which the distribution network provider can access at any time.

Applied rules and standards:

C10/11:2012-06

Specific technical requirements for generator in parallel operation with the distribution network

DIN V VDE V 0126-1-1/A1:2012-02

Automatic disconnection device between a generator and the public low-voltage grid; Amendment 1

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report number: SXP-16DE1261FTSP

Certificate number: U17-0048

Date of issue: 2017-02-07



Certification body

Dieter Zitzmann

Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to DIN EN ISO/IEC 17065

